



# ADMINISTRATIVE OFFICE OF THE COURTS

MARYLAND JUDICIAL CENTER  
580 TAYLOR AVENUE  
ANNAPOLIS, MARYLAND 21401

Pamela Harris, State Court Administrator  
410-260-1295

Faye D. Matthews  
Deputy State Court Administrator  
410-260-1257

Mark Bittner  
Assistant Administrator  
Judicial Information Systems  
410-260-1001

Louis G. Gieszl  
Assistant Administrator  
Programs  
410-260-3547

Melinda K. Jensen, CPA  
Assistant Administrator  
Operations  
410-260-1240

Stephane J. Latour, Esq.  
Managing Legal Counsel/  
Assistant Administrator  
Internal Affairs  
410-260-3453

Kelley O'Connor  
Assistant Administrator  
Government Relations  
410-260-1560

## Questions/Responses No. 1 to the Request for Proposal (RFP) Exterior/Interior Security Cameras K15-0052-83F June 4, 2015

Ladies and Gentlemen:

The following questions for the above referenced RFP were received and are answered and posted for all prospective Contractors who received the RFP. The statements and interpretations contained in the following responses to questions are not binding on the Maryland Judiciary unless the RFP is expressly amended. Nothing in the Maryland Judiciary's response to these questions is to be construed as agreement to or acceptance by the Maryland Judiciary of any statement or interpretation on the part of the Contractor asking the question.

**Question:** Civil Building- Cashier's office: should wire be installed in conduit or EMT?

**Response:** Wiring must not be exposed, but does not need to be encased in EMT.

**Question:** Civil Building- Cashiers office: are there 4 or 6 cameras?

**Response:** There are six (6) existing cameras in the cashier's office. All six (6) cameras shall be replaced.

**Question:** Can past performance of the Prime and its team i.e. potential subcontractor can satisfy the past performance requirement or does the Prime have to have all of the past performance?

**Response:** Please see section 3 page 18 line item 3.4.9.

Date Issued: June 4, 2015

Issued by: Lisa Peters, Procurement Officer

